

## For Residential and Commercial Applications

Job Name \_\_\_\_\_

Contractor \_\_\_\_\_

Job Location \_\_\_\_\_

Approval \_\_\_\_\_

Engineer \_\_\_\_\_

Contractor's P.O. No. \_\_\_\_\_

Approval \_\_\_\_\_

Representative \_\_\_\_\_

# LEAD FREE\*

## Poly-Alloy CrimpRing™ Test Plugs

Poly-Alloy CrimpRing™ Test Plugs are used for pressure testing the system.

### Specifications

System shall be plumbed using Watts WaterPEX® cross-linked polyethylene pipe, and all joints shall be made using Watts brass CrimpRing™ and/or poly-alloy CrimpRing™ fittings using either the Watts copper CrimpRing™ or stainless steel CinchClamp™\*\* crimping methods as outlined in the Watts WaterPEX® Installation Guidelines.

### Installation Note

CrimpRing™ Test Plugs must be installed in accordance with all Watts WaterPEX® installation procedures, including information provided in WaterPEX® installation manual and guidelines.

### Approvals



- Manufactured in accordance with American Society for Testing and Materials (ASTM) F-877 and F-2159
- Listed by the National Sanitation Foundation to NSF Standards 14 and 61 for use in potable water systems
- Listed by NSF to be in compliant to the Uniform Plumbing Code
- Labeled B137.5 which indicates that it is compliant to the CSA Standards B137.5
- Manufactured from Acudel® engineered thermoplastic resin

\*The wetted surface of this product contacted by consumable water contains less than one quarter of one percent (0.25%) of lead by weight.

\*\*Note: Watts WaterPEX CinchClamp™ fittings should not be used with wrought copper PEX fittings.



WP27P  
CrimpRing™ Test Plug

### Dimensions – Weights

MODEL	CONNECTION		type	PKG. WEIGHT	
	in.	mm		lbs.	kgs.
WP27P-06PB	3/8	10	Crimp Fitting	1	0.4
WP27P-08PB	1/2	15	Crimp Fitting	1	0.4
WP27P-12PB	3/4	20	Crimp Fitting	2	0.9
WP27P-16PB	1	25	Crimp Fitting	2	0.9

### Warning!

If connections must be made in temperatures below 30°F, caution must be taken to allow the WaterPEX to form a proper seal against the barb. Apply the connection slowly to ensure the PEX material conforms to the barb.

Watts product specifications in U.S. customary units and metric are approximate and are provided for reference only. For precise measurements, please contact Watts Technical Service. Watts reserves the right to change or modify product design, construction, specifications, or materials without prior notice and without incurring any obligation to make such changes and modifications on Watts products previously or subsequently sold.

ISO 9001-2008  
CERTIFIED



USA: 815 Chestnut St., No. Andover, MA 01845-6098; www.watts.com

Canada: 5435 North Service Rd., Burlington, ONT. L7L 5H7; www.wattscanada.ca

ES-WP-PATestPlugs 1020

# WATTS®

A Watts Water Technologies Company

© 2010 Watts